

STATE OF ALABAMA

DEPTARTMENT OF FINANCE DIVISION OF PURCHASING

INVITATION TO BID ADDENDUM

FOR: GENERATOR 150KW DISTRICT 5

KATHY SNOW

REQ. AGENCY : 012013

ALDOT - 3RD DIV : 301-030089

AGENCY REQ. NO. : 301-030089

T-NUMBER

DATE ISSUED : 02/05/10

VENDOR NO. VENDOR PHONE NO.

SNAP REQ. NO. : 1432659

BUYER NAME : RAY BRESSLER BUYER PHONE NO. : (334) 242-4670

BID MUST BE RECEIVED BEFORE: DATE: 02/18/10 TIME: 5:00 PM

BIDS WILL BE PUBLICLY OPENED: DATE: 02/19/10 TIME: 10:00 AM

PLEASE READ ALL INSTRUCTIONS CAREFULLY

THE FOLLOWING CHANGES ARE HEREBY ADDED TO AND MADE A PART OF (INVITATION TO BID NUMBER 2215557)

THE FOLLOWING CHANGES TO THIS SOLICITATION SPECIFICATIONS ARE BELOW. PAGE 4, PARAGRAPH 3.2, FIRST SENTENCE: CHANGE TO READ AS FOLLOWS, "THE TRANSFER SWITCHES, ONE 400 AMP AND ONE 300 AMP, SHALL BE A 3-POLE DESIGN RATED FOR 400 AMP CONTINUOUS OPERATION IN AMBIENT TEMPERATURES OF -20 DEGREES FAHRENHEIT (-30 DEGREES CELSIUS) TO +140 DEGREES FAHRENHEIT (+60 CELSIUS)."

PAGE 5, PARAGRAPH 5.4.1: ADD THIS STATEMENT, "THE GENERATOR WILL BE MOUNTED ON A CONCRETE PAD FURNISHED BY THE CONTRACTOR AND SHALL BE LOCATED INSIDE THE FENCED AREA."

STATEMENT OF UNDERSTANDING

I UNDERSTAND THE ADDENDUM AND THAT IT MUST BE SIGNED IN INK AND RETURNED (UNLESS INDICATED OTHERWISE) WITH THE BID OR SEPARATELY, PROPERLY IDENTIFIED AND RECEIVED PRIOR TO DATE AND TIME SPECIFIED.

	COMPANY NAME	AUTHORIZED SIGNATURE (INK
ADDENDUM NOTARIZATION NOT REQUIRED	MAIL ADDRESS	TYPE/PRINT AUTHORIZED NAM
	CITY, STATE, ZIP	
	PHONE INCLUDING AREA CODE	